



The mentioned product  
complies with the mentioned  
test requirement

# Intertek LSS Scheme Tick Mark Certificate

Tick Mark Certificate No: 19LHK2620-01

This is to certify that:

## Siterwell GS828 Carbon Monoxide Alarm

is in conformity with the following standard(s):

EN 50291-1:2010+A1:2012

Report Number(s):

180904033GZU-001

**Siterwell Electronics Co., Limited**

No.666 Qingfeng Road, Jiangbei District, Ningbo, Zhejiang Province, China

and is authorised to use the Intertek Tick Mark for the LSS Scheme on the  
above mentioned product(s)

This certificate is valid until:

**26 February 2021**

This Certificate is issued in accordance with the Certification Regulations governing its use and in reliance on the undertaking given by the Licensee and only extends to the use in respect of the goods produced to an acceptable degree of compliance with the Approval Standard. This Certificate is not transferable and remains the property of Intertek Testing and Certification Ltd.

<b>Limitations:</b>	<b>Certification Body:</b> ITCL
Recommended battery change after 3 years.	<b>LSS Reference:</b> LSS 1030
	<b>Issued Date:</b> 23 April 2020

Signed on behalf of Intertek, located at Leatherhead, United Kingdom



Certification Officer

Nick Jones



# Intertek LSS Scheme Tick Mark Certificate

Tick Mark Certificate No: 19LHK2620-01

The mentioned product complies with the mentioned test requirement

The tested product fulfils the criteria based on the Intertek Tick Mark Specification according to the guideline and is therefore awarded the Intertek Tick Mark. The Intertek Tick Mark may be used by the applicant in connection with sales and marketing in order to demonstrate and verify the performance of the tested product.

## ANNEX No. 1

Brand and Type/Model	Description	Factory Code
SITERWELL GS828	Carbon monoxide alarm	SITERWCN.01

## ANNEX No. 2

Model GS828 is a Type B electrochemical carbon monoxide alarm for domestic premises.

Manufacturer's declared expected lifetime of this CO alarm is 7 Years.

Carbon monoxide alarm specification:

CO Sensor Type: Electrochemical

Power Source: DC3V 2x1.5V, Alkaline AA; Gold Peak GN15A , Raymax LR6 replaceable battery

This Certificate is for the exclusive use of Intertek's Client and is provided pursuant to the Certification agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this certificate. Only the Client is authorised to permit copying or distribution of this certificate and then only in its entirety. Use of Intertek's Certification mark is restricted to the conditions laid out in the agreement. Any further use of the Intertek name for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. Initial Factory Assessments and Follow up Services are for the purpose of assuring appropriate usage of the Certification mark in accordance with the agreement, they are not for the purposes of production quality control and do not relieve the Client of their obligations in this respect.