

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190919-EX28013  
**Report Reference** EX28013-20190916  
**Issue Date** 2019-SEPTEMBER-19

**Issued to:** Armas Su Armaturleri San. Ve. Tic A.S.  
1. Organize Sanayi Bolgesi, Atabey Sokak No:11/A  
42300 Konya TURKEY

**This certificate confirms that  
representative samples of**

DRAIN FITTINGS, SPECIAL TYPE  
See Addendum Page for models

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

UL258, Investigation for shutoff Valves for Trim and Drain  
Purposes  
ULC C258-03, Shutoff Valves for Trim and Drain Purposes  
UL199, Automatic Sprinklers for Fire-Protection Service  
ULC C199-03, Automatic Sprinklers for Fire-Protection  
Service

**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



# CERTIFICATE OF COMPLIANCE

Certificate Number 20190919-EX28013  
Report Reference EX28013-20190916  
Issue Date 2019-SEPTEMBER-19

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model TD test and drain fitting in the following nominal sizes, discharge coefficients and rated pressures:

Size, in.	Nominal K-Factor, $\text{gpm}/(\text{psi})^{1/2}$	Rated Pressure, psig
1	5.6	300
1-1/4	5.6, 8.0	300
1-1/2	5.6, 8.0	300
2	5.6, 8.0	300



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

